

HP_DOSO_NUOSXL_T6.2024

Thời gian	FLOW OUT (39.58)	FLOW_IN	pH (6-9)	TSS (49.5)	TEMP (40)	COD (74.25)	NH4-N (4.95)
	<i>m3/h</i>	<i>m3/h</i>		<i>mg/L</i>	<i>oC</i>	<i>mg/L</i>	<i>mg/L</i>
01-06-2024	22.89	41.22	7.37	8.92	30.96	33.35	0.29
02-06-2024	0.26	0.39	7.65	10.82	31.05	26.53	0.36
03-06-2024	2.03	39.72	7.33	9.61	30.44	25.26	0.39
04-06-2024	16.62	43.48	7.07	9.21	31.4	25.11	0.34
05-06-2024	19.54	38.31	7.05	14.64	31.49	26.41	0.23
06-06-2024	34.4	49.76	7.17	7.27	30.04	15.55	0.14
07-06-2024	36.47	54.15	7.24	7.77	30.41	4.4	0.1
08-06-2024	27.73	45.25	7.28	11.51	29.96	11.58	0.17
09-06-2024	33.86	55.49	7.22	6.25	29.19	9.88	0.26
10-06-2024	35.97	59.53	7.12	6.81	28.72	9.8	0.39
11-06-2024	33.23	48.96	7.22	7.39	30.09	11.31	0.53
12-06-2024	28.78	40.84	7.28	8.2	31.09	11.64	0.48
13-06-2024	27.4	40.94	7.17	9.91	31.88	13.62	0.38
14-06-2024	27.07	36.44	7.09	10.62	31.96	18.54	0.36
15-06-2024	23.35	34.29	7.17	8.85	32.48	18.62	0.32
16-06-2024	20.84	26.38	7.09	8.5	33.53	29.36	0.28
17-06-2024	22.93	30.65	7.12	9.36	33.16	33.88	0.22
18-06-2024	30.5	40.24	7.23	18.22	33.06	30.77	0.21
19-06-2024	25.09	35.69	7.04	-	33.11	33.42	0.3
20-06-2024	32.83	35.49	7.04	8.55	33.08	35.44	0.29
21-06-2024	34.78	41.52	6.87	6.73	33.36	33.07	0.48
22-06-2024	35.19	43.91	6.93	6.79	33.39	24.26	0.45
23-06-2024	21.53	28.86	6.99	7.57	33.01	22.91	0.39
24-06-2024	38.72	54.48	7.17	7.06	30.29	18.67	0.39
25-06-2024	32.72	46.46	6.96	8.97	30.58	20.72	0.59
26-06-2024	27.84	44.25	6.97	7.71	30.08	8.57	0.7
27-06-2024	26.81	43.11	7.05	7.84	30.48	8.71	0.75
28-06-2024	33.1	50.35	7.2	9.95	30.59	13.09	0.75
29-06-2024	27.13	47.43	7.18	8.75	31.06	13.28	0.71
30-06-2024	26.89	37	7.2	9.62	31.58	15.24	0.72