

HP_DOSO_NUOSXL_T7.2024

Thời gian	FLOW OUT	FLOW IN	PH (6-9)	TSS (49.5)	TEMP (40)	COD (74.25)	NH4-N (4.95)
	<i>m3/h</i>	<i>m3/h</i>		<i>mg/L</i>	<i>oC</i>	<i>mg/L</i>	<i>mg/L</i>
01-07-2024	29.7	37.99	7.08	10.6	31.67	18.83	0.75
02-07-2024	32.79	44.55	7.33	11.36	31.78	19.56	0.68
03-07-2024	31.61	41	7.31	9.63	32.07	18.49	0.72
04-07-2024	32.37	37.81	7.13	6.96	32.07	30.7	0.64
05-07-2024	29.59	40.18	7.12	7.84	32.33	21.86	0.68
06-07-2024	31.86	48.32	7.17	8.63	32.35	22.64	0.69
07-07-2024	28.39	36.94	7.03	11.73	32.45	19.85	0.85
08-07-2024	25.67	32.22	7.1	13.44	32.32	23.02	0.86
09-07-2024	33.25	39.5	7.1	7.4	32.08	45.4	0.79
10-07-2024	31.65	36.2	7.03	8.51	32.2	36.15	0.64
11-07-2024	30.74	35.28	7.01	10.98	32.66	40.8	0.53
12-07-2024	31.21	37.21	7.12	11.25	32.7	43.78	0.51
13-07-2024	31.57	40.87	7.07	8.56	32.6	51.82	0.57
14-07-2024	18.33	26.14	7.09	8.02	32.75	41.82	0.58
15-07-2024	16.21	26.96	7.03	8.12	32.94	40.37	0.55
16-07-2024	29.25	40.33	7.03	9.08	33.14	39.89	0.55
17-07-2024	36.39	46.8	6.93	9.35	32.62	45.32	0.53
18-07-2024	34.4	49.75	7.03	10.07	31.32	27.49	0.58
19-07-2024	34.21	51.82	7.12	13.14	32.27	8.45	0.77
20-07-2024	31.24	42.18	7.12	7.58	32.03	7.92	0.79
21-07-2024	35.15	47.63	7.2	8.31	32.27	16.74	0.83
22-07-2024	36.41	46.53	7.24	7.11	32.17	22.63	0.53
23-07-2024	31.99	35.26	7.42	11.63	29.43	22.44	0.43
24-07-2024	34.49	49.29	7.42	8.82	29.82	11.63	0.39
25-07-2024	34.92	49.46	7.35	7.45	29.97	24.9	0.44
26-07-2024	35.28	48.18	7.27	8.27	30.65	13.78	0.36
27-07-2024	25.52	34.26	7.31	8.22	31.24	14.43	0.38
28-07-2024	29.19	34.19	7.28	8.45	32.21	19.82	0.33
29-07-2024	31.34	37.98	7.17	7.98	31.57	16.09	0.3
30-07-2024	35.44	43.94	7.01	8.72	29.89	13.78	0.27
31-07-2024	39.68	50.02	7.17	8.42	29.76	9.86	0.42